



Nabholz Construction
17300 W 116th St
Lenexa, KS 66219

Project: **CP180131- University of Missouri Healthcare- Women's and Children's Hospital
Exterior Envelope Replacement**

Bid Date & Time: **7/31/2019 @ 1:30PM**

Bid Captain: Daniel Dercher – daniel.dercher@nabholz.com
Mitchell Fuemmeler – mitchell.fuemmeler@nabholz.com

ADDENDUM NOTICE

Addendum #3 has been issued

The following is included in Addendum #3:

- **Clarification: Addendum #2 Specification Changes #2**, Section 074213.19, Paragraph 2.2B.1.b, Delete and Replace with: Benchmark by Kingspan – Designwall 4000 Panel Series. 720 Marion Road, Columbus, OH 43207.
- **Clarification: Addendum #2 RFI Response #21** – Type X is not required, but substrate board is required.
- **Construction Manager's Manual Clarifications:**
 - 3.00 Bid Packages and Bid Forms
 - **07.3 Roofing, Flashing & Sheet Metal Bid Package**
 - Applicable Specifications, ADD: Section 061000 – Rough Carpentry
 - Section D, ADD: Top of parapet blocking will be by others in future package. All other roof blocking to be by roofing contractor.

Acknowledgement of all addenda is a requirement of the bid process. Please acknowledge this and all addenda on the Bid Form found in section 3.00.02 of the Construction Manager's Manual.

Should you have any questions concerning this project, please contact the Bid Captain noted above.

Daniel Dercher
Senior Estimator